



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208

Miami, Florida 33175-2474

T (786) 315-2590 F (786) 315-2599

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

## NOTICE OF ACCEPTANCE (NOA)

Cooley, Inc.  
50 Esten Avenue  
Pawtucket, RI 02860

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION:** Cooley C3, C3FB and C3Plus PVC Single Ply Roof Systems over Cementitious Wood Fiber Decks

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This revises NOA# 11-0314.03 and consists of pages 1 through 10.  
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 12-0823.03  
Expiration Date: 08/03/16  
Approval Date: 06/13/13  
Page 1 of 10

## ROOFING SYSTEM APPROVAL

|                                |                         |
|--------------------------------|-------------------------|
| <b>Category:</b>               | Roofing                 |
| <b>Sub-Category:</b>           | Single Ply              |
| <b>Material:</b>               | PVC                     |
| <b>Deck Type:</b>              | Cementitious Wood Fiber |
| <b>Maximum Design Pressure</b> | -45 psf                 |

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

**TABLE 1**

| <b><u>Product</u></b>                        | <b><u>Dimensions</u></b>   | <b><u>Test Specification</u></b>        | <b><u>Product Description</u></b>   |
|--|--|---|---|
| Cooley C-3 40-100 Mil Membrane               | 78" x 108"<br>702 sf. roll   | ASTMD 4434                              | 40-100 mil thermoplastic alloy membrane field membrane.                           |
| Cooley C-3 40-100 Mil Perimeter Sheet        | 39" x 108'<br>351 sf. roll   | ASTM D 4434                             | 40-100 mil thermoplastic alloy membrane perimeter sheet.                          |
| Cooley C-3 Plus 40-100 Mil Membrane          | 78" x 100'<br>650 ft. <sup>2</sup> roll  | ASTMD 4434                              | 40-100 mil thermoplastic alloy membrane field membrane.                           |
| Cooley C-3 Plus 40-100 Mil Perimeter Sheet   | 39" x 100'<br>325 ft. <sup>2</sup> roll  | ASTMD 4434                              | 40-100 mil thermoplastic alloy membrane perimeter sheet.                          |
| Cooley C-3 Reinforced Flashing Membrane      | 6", 8", 12", 18" &<br>24" variable length<br>rolls                                 | ASTM D 4434                             | 40-100 mil thermoplastic flashing membrane.                                       |
| Cooley C-3 Coated Metal                      | 4' x 8'<br>4' x 10' sheets   | US Commercial<br>Standard CS-<br>245-62 | C-3 membrane laminated 24 Ga. galvanized steel.                                   |
| Cooley C-3 Fleece Back RAM                   | 76" x 100'<br>39" x 100'<br>325 ft. <sup>2</sup> roll                              | ASTM D 4434                             | Thermoplastic fleece back membrane. Adhered applications.                         |
| Cooley C-3 Fleece Back RAM Flashing          | 12" x 100'<br>100 ft. <sup>2</sup> roll<br>24" x 100'<br>200 ft. <sup>2</sup> roll | ASTM D 4434                             | Thermoplastic fleece back membrane flashing material.                             |
| Cooley C-3 Fleece Back RAM Universal Corners | 14" x 14"  | ASTM D 4434                             | Thermoplastic fleece back membrane. Adhered applications.                         |
| Cooley C3 Bonding Adhesive                   | 5 gallon pails   | proprietary                             | Solvent based adhesive for fully adhered RAM systems and C3PLUS roofing membrane. |
| Cooley WB Bonding Adhesive                   | N/A  | proprietary                             | Water Based adhesive for fully adhered C3PLUS Roofing Membrane.                   |
| Cooley Coolgrip Walkway                      | 0.072" x 36" x 60'   | proprietary                             | Walkway pad (roll configuration)  |
| Cooley Coolgrip Heavy Duty Walkway           | 0.150" x 36" x 60'   | proprietary                             | Walkway pad (roll configuration)  |

**APPROVED INSULATIONS:****TABLE 2**

| <b><u>Product Name</u></b>               | <b><u>Product Description</u></b>          | <b><u>Manufacturer<br/>(With Current NOA)</u></b> |
|--|--|---|
| Pyrox, White Line                        | Isocyanurate Insulation                    | Apache Products Co.                               |
| ACFoam II, III                           | Isocyanurate Insulation                    | Atlas Roofing Corp.                               |
| Conperl                                  | Perlite insulation board.                  | Conglas   |
| Hytherm, Hytherm AP                      | Isocyanurate Insulation                    | Dow Chemical                                      |
| Styrofoam                                | Extruded Polystyrene.                      | Dow Chemical                                      |
| ISO 95+, ISO 95+ GL                      | Polyisocyanurate foam insulation           | Firestone   |
| EnergyGuard High Density Fiberboard      | High density wood fiberboard insulation.   | GAF Materials Corp.                               |
| EnergyGuard Perlite                      | Perlite insulation board.                  | GAF Materials Corp.                               |
| Aarmor Board High Density                | Wood fiber insulation board.               | Honeywell International                           |
| Dens Deck, Dens Deck Prime               | Silicon treated gypsum                     | G-P Products                                      |
| Sturdi-Top, Roof Insulation Board        | Wood fiber insulation board.               | G-P Products                                      |
| High Density Wood Fiberboard             | High Density Wood Fiber insulation board.  | Generic   |
| Perlite Insulation Board                 | Perlite Insulation                         | Generic   |
| Type X Gypsum, Gypsum                    | Gypsum Wallboard                           | Generic   |
| EPS or XPS Insulation                    | Expanded or Extruded Polystyrene.          | Generic   |
| Ultra/M-II                               | Isocyanurate Insulation                    | Homasote Co.                                      |
| H-Shield                                 | Isocyanurate Insulation                    | Hunter Panels                                     |
| ENRGY 2, ENERGY 3, PSI-25                | Isocyanurate Insulation                    | Johns Manville                                    |
| UltraGuard                               |  |   |
| Fesco Foam, DuraFoam                     | Isocyanurate Insulation with perlite facer | Johns Manville                                    |
| Fesco Board                              | Rigid perlite roof insulation board.       | Johns Manville                                    |
| Strataguard                              | Gypsum Wallboard                           | Owens Corning                                     |
| Multi-Max, Multi-Max FA, Thermoarof Plus | Polyisocyanurate foam insulation           | Rmax, Inc.  |
| Fiberbase HD1, HD6                       | Asphalt coated wood fiber insulation       | Temple Inland Forest Products Corp.               |
| Structodeck                              | High Density Wood Fiber insulation board.  | Wood Fiber Industries                             |

**APPROVED FASTENERS:****TABLE 3**

| <b><u>Fastener Number</u></b> | <b><u>Product Name</u></b>    | <b><u>Product Description</u></b>           | <b><u>Dimensions</u></b>         | <b><u>Manufacturer (With Current NOA)</u></b> |
|-------------------------------|-------------------------------|---|----------------------------------|---|
| 1.                            | NTB Magnum                    | Fastener for cementitious and gypsum decks. | Various                          | Olympic Mfg. Group                            |
| 2.                            | NTB Plate                     | Round Galvalume AZ55 stress plate           | 3" round                         | Olympic Mfg. Group                            |
| 3.                            | NTB Metal Barbed Stress Plate | Round Galvalume AZ55 stress plate           | 2" round                         | Olympic Mfg. Group                            |
| 4.                            | NTB Plastic Plate             | Plastic plates for NTB 2" head fasteners.   | 3" round                         | Olympic Mfg. Group                            |
| 5.                            | Twin-Loc Locking Impact Nail  | Base sheet fastener with integrated Plate.  | Length: 1.8"<br>Plate Dia.: 2.7" | ES Products, Inc.                             |

**EVIDENCE SUBMITTED:**

| <b><u>Test Agency/Identifier</u></b> | <b><u>Report</u></b> | <b><u>Name</u></b> | <b><u>Date</u></b> |
|--------------------------------------|----------------------|--------------------|--------------------|
| Factory Mutual Corp.                 | 3025170              | 4470               | 02/07/06           |
|                                      | 3021133              | 4470               | 02/07/06           |
|                                      | J.I. 0X2A9.AM        | 4470               | 06/26/93           |
|                                      | J.I. 3W1A1.AM        | 4470               | 03/29/93           |
|                                      | J.I. 1W1A9.AM        | 4470               | 09/11/93           |
|                                      | J.I. 1X3A6.AM        | 4470               | 10/03/93           |
|                                      | J.I. 1W9A2.AM        | 4470               | 06/15/93           |
|                                      | J.I. 1W2A0.AM        | 4470               | 08/24/93           |
|                                      | J.I. 1T2A6.AM        | 4470               | 02/22/93           |
|                                      | J.I. 3W3A4.AM        | 4470               | 03/26/93           |
|                                      | J.I. 0X8A9.AM        | 4470               | 06/25/93           |
|                                      | J.I. 1X6A5.AM        | 4470               | 10/12/93           |
|                                      | J.I. 2W5A6.AM        | 4470               | 06/01/93           |
| Underwriters Laboratories, Inc.      | File R9834 (N)       | UL 790             | 04/06/93           |
| Momentum Technologies, Inc.          | NX21J0A              | ASTM D 4434        | 06/01/11           |
|                                      | NX21J0B              | ASTM D 4434        | 07/20/11           |
|                                      | NX21J0C              | ASTM D 4434        | 06/01/11           |

**APPROVED ASSEMBLIES**

- Membrane Type:** Single Ply, PVC
- Deck Type 5I:** Cementitious Wood Fiber, Insulated
- Deck Description:** Cementitious wood fiber
- System Type A:** Anchor sheet mechanically attached, insulation adhered and membrane adhered.

**All General and System Limitations apply.**

**Anchor Sheet:** One ply of Miami-Dade Approved ASTM D 4601 membrane secured to the deck with Olympic NTB Magnum fasteners at 1 per 2 sq. ft.

One or more layers of the Base Layer insulation covered by one layer of the insulation listed as Top Layer.

| <u>Base Insulation Layer</u>  | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener</u><br><u>Density/ft<sup>2</sup></u> |
|---|---|--|
| ACFoam II, Multi-Max FA, ENRGY-2, ENRGY-3, PSI-25, ISO-95+, ISO + GL, Hy-Therm AP, Pyrox<br>Minimum 1.4” thick  | N/A   | N/A  |
| <u>Top Insulation Layer</u>   | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener</u><br><u>Density/ft<sup>2</sup></u> |
| High Density Fiberboard, FM-90 High Density, Armor Board Regular, Esgard, EnergyGuard Fiberboard,<br>Huebert Fiberboard, Kop-R Wood Fiber<br>Minimum ½” thick | N/A   | N/A  |

**Note:** All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup> or Cooley C3 Bonding Adhesive at 1 gal./sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

- Membrane:** C3 Fleece Back Roof Cover fully adhered to the insulation with Cooley C3 Bonding Adhesive applied at the rate of 1 gal./sq., or approved mopping asphalt applied at the rate of 25 lbs./sq.
- Maximum Design Pressure:** -45 psf; (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC  
**Deck Type 5I:** Cementitious Wood Fiber, Insulated  
**Deck Description:** Cementitious wood fiber  
**System Type C(1):** All layers of insulation simultaneously attached; C3 Plus membrane fully adhered.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

| <b><u>Insulation Layer</u></b>  | <b><u>Insulation Fasteners<br/>(Table 3)</u></b> | <b><u>Fastener Density/ft<sup>2</sup></u></b> |
|---|--|---|
| <b>ISO 95+ GL, ENRGY 3, PSI 25, ValuTherm<br/>Minimum 2" thick</b>  | See Note below                                   | 1: 2 ft <sup>2</sup>                          |
| <b>ACFoam II, ACFoam III, Hy-Therm AP, Kop R<br/>Minimum 1.5" thick</b>   | See Note below                                   | 1: 2 ft <sup>2</sup>                          |
| <b>Fiber Top E<br/>Minimum 0.75" thick</b>  | See Note below                                   | 1: 2 ft <sup>2</sup>                          |
| <b>High Density Fiberboard, Armor Board Regular and High Density, Esgard and Esgard High Strength, EnergyGuard High Density Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber, GAFTEMP Fiberboard, Knight-Celotex Fiberboard Premium and High Density, High Density Roof Board, Fiber Top C<br/>Minimum 1" thick</b> | See Note below                                   | 1: 2 ft <sup>2</sup>                          |

**Note:** All layers shall be simultaneously fastened with Polymer Gyptec fastener and plate, Firestone Polymer fastener and Insulation plate, Powerlite or Olympic GTL, Lite-Deck or NTB Magnum fastener and plate all with minimum 2" deck penetration. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation.

**Vapor Retarder:** (Optional) Any UL or FM approved vapor retarder applied to the roof deck or over a base layer of insulation.

**Fire Barrier:** (Optional) Minimum 1/4" Dens Deck secured to the deck with the insulation.

**Membrane:** C3 Plus Membrane fully adhered to the insulation with Cooley C3 Bonding Adhesive applied at the rate of 0.83 gal./sq. on both the membrane and the substrate for a total of 1.67 gal./sq., and a heat welded seam minimum 1½" wide at the laps or Cooley WB Bonding Adhesive applied at the rate of 0.67 gal/sq to the substrate.

**Maximum Design Pressure:** -45 psf; (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC  
**Deck Type 5I:** Cementitious Wood Fiber, Insulated  
**Deck Description:** Cementitious wood fiber  
**System Type C(2):** All layers of insulation simultaneously attached; C3 Plus membrane fully adhered.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

**Note: All layers shall be simultaneously fastened with minimum 1" deck penetration. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

| <u>Insulation Layer</u>   | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| ENRGY 3, PSI 25, ValuTherm, ISO 95+ GL<br>Minimum 2" thick  | 5   | 1: 33 ft <sup>2</sup>                  |
| ACFoam II, ACFoam III Hy-Therm AP, Kop R<br>Minimum 1.5" thick  | 5   | 1: 33 ft <sup>2</sup>                  |
| Fiber Top E<br>Minimum 0.75" thick  | 5   | 1: 33 ft <sup>2</sup>                  |
| High Density Fiberboard, Armor Board Regular and High Density, Esgard and Esgard High Strength, EnergyGuard High Density Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber, GAFTEMP Fiberboard, Knight-Celotex Fiberboard Premium and High Density, High Density Roof Board, Fiber Top C<br>Minimum 1" thick | 5   | 1: 33 ft <sup>2</sup>                  |

**Vapor Retarder:** (Optional) Any UL or FM approved vapor retarder applied to the roof deck or over a base layer of insulation.

**Fire Barrier:** (Optional) Minimum 1/4" Dens Deck secured to the deck with the insulation.

**Membrane:** C3 Plus Membrane fully adhered to the insulation with Cooley C3 Bonding Adhesive applied at the rate of 0.83 gal./sq. on both the membrane and the substrate for a total of 1.67 gal./sq., and a heat welded seam minimum 1½" wide at the laps or Cooley WB Bonding Adhesive applied at the rate of 0.67 gal/sq to the substrate.

**Maximum Design Pressure:** -45 psf; (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC  
**Deck Type 5I:** Cementitious Wood Fiber, Insulated  
**Deck Description:** Cementitious wood fiber  
**System Type C(3):** All layers of insulation simultaneously fastened; membrane fully adhered.

**All General and System Limitations apply.**

One or more layers of the Base Layer insulation covered by one layer of the insulation listed as Top Layer.

| <b><u>Base Insulation Layer</u></b>  | <b><u>Insulation Fasteners</u><br/><u>(Table 3)</u></b> | <b><u>Fastener</u><br/><u>Density/ft<sup>2</sup></u></b> |
|--|---|--|
| ACFoam II, Multi-Max FA, ENRGY-2, ENRGY-3, PSI-25, ISO-95+, ISO + GL, Hy-Therm AP, Pyrox<br>Minimum 1.4" thick | N/A   | N/A  |

**Note:** All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

| <b><u>Top Insulation Layer</u></b>                                    | <b><u>Insulation Fasteners</u><br/><u>(Table 3)</u></b> | <b><u>Fastener</u><br/><u>Density/ft<sup>2</sup></u></b> |
|---|---|--|
| ISO 95 +, ISO 95 + GL, ENRGY-2, ENRGY-3, PSI-25<br>Minimum 1.4" thick | 1   | 1:2 ft <sup>2</sup>                                      |
| ACFoam II, Multi-Max FA<br>Minimum 1.5" thick                         | 1   | 1:2 ft <sup>2</sup>                                      |

**Vapor Retarder:** (Optional) Any UL or FM approved vapor retarder applied to the roof deck or over a base layer of insulation.

**Fire Barrier:** (Optional) Minimum ½" or Dens Deck secured to the deck with the insulation.

**Membrane:** C3 Fleece Back Roof Cover fully adhered to the insulation with Cooley C3 Bonding Adhesive applied at the rate of 1 gal./sq., or approved mopping asphalt applied at the rate of 25 lbs./sq.

**Maximum Design Pressure:** -45 psf; (See General Limitation #9.)





**Membrane Type:** Single Ply, PVC  
**Deck Type 5:** Cementitious Wood Fiber, Non-Insulated  
**Deck Description:** Cementitious wood fiber  
**System Type E:** Anchor sheet mechanically attached, membrane adhered.

**All General and System Limitations apply.**

**Anchor Sheet:** One ply of Miami-Dade Approved ASTM D 4601 membrane secured to the deck with Olympic NTB Magnum fasteners at 1 per 2 sq. ft.

**Membrane:** C3 Fleece Back Roof Cover fully adhered to the anchor sheet with Cooley C3 Bonding Adhesive applied at the rate of 1 gal./sq., or approved mopping asphalt applied at the rate of 25 lbs./sq.

**Maximum Design Pressure:** -45 psf; (See General Limitation #9.)



**NOA No.: 12-0823.03**  
**Expiration Date: 08/03/16**  
**Approval Date: 06/13/13**  
**Page 9 of 10**

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.  
**Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.

## END OF THIS ACCEPTANCE